

School of Business
Building Abbreviation: BUSN

Entrance Information:

- Accessible entrances on North side of building facing Fairfield Way, and West side facing Hillside Road
- Automatic door openers
- Campus phone is present near the west accessible entrance



North Entrance



West Entrance

Bathroom Information:

	Floor(s)	Width of Accessible Stall Door?	Stall is 60" wide X 56" deep?	Grab Bars in Accessible Stall?	Height of Toilet is at least 19"?
Men	1-4	33 inches	Yes	Yes	17"
Women	1-4	33 inches	Yes	Yes	17"

Elevator in building: Yes